



FUSS & O'NEILL
Manufacturing Solutions, LLC
"Enhancing Productivity"

X	Basic Skill
X	Counter Measure
X	Accessibility
X	Safety
O	Mistake Proofing
X	Productivity

Positive Pressure for Electrical Cabinets (Safe Vs. Un-Safe)

Due to many un-planned breakdowns, over – heated electrical components failed.

Root Cause determined that the muffin fans were broken.

The wrong band-aid, placing a floor fan to cool the cabinet...

Employees should never leave an electrical cabinet open !!!



Un-Safe

With new muffin fans installed, verify air flow out of electrical cabinet w/ streamer.



Safe

4